


GENERAL NOTES:


1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECTS AND STRUCTURAL ENGINEERS CONSTRUCTION ISSUE DRAWINGS, FIRE CERTIFICATE & FIRE DRAWINGS, ALONG WITH THE CONSULTANTS MECHANICAL AND ELECTRICAL SPECIFICATIONS AND ANY OTHER DOCUMENTATION.
2. DO NOT SCALE FROM THIS DRAWING. THIS DRAWING IS REPRESENTATIVE ONLY. ALL DIMENSIONS ARE IN MILLIMETERS (mm), UNLESS OTHERWISE STATED. USE THE FIGURED DIMENSIONS WHEN SHOWN.
3. THE EXACT LOCATION OF SERVICES AND FITTINGS TO BE AGREED ON SITE WITH THE ARCHITECT AND/OR MECHANICAL OR STRUCTURAL ENGINEER PRIOR TO THEIR INSTALLATION.
4. THE MECHANICAL AND ELECTRICAL SERVICES ARE TO BE CO-ORDINATED WITH ALL OTHER TRADES AND TO BE AGREED ON SITE PRIOR TO THEIR INSTALLATION. THE CONTRACTOR SHALL ALLOW FOR THE SETTING OUT AND INSTALLATION AROUND ALL OBSTRUCTIONS. ADDITIONAL COSTS INCURRED BY THE CONTRACTOR DUE TO THE LACK OF CO-ORDINATION WILL NOT BE ENTERTAINED.
5. CONNECTIONS TO ALL EQUIPMENT TO BE MADE BY THE CONTRACTOR.
6. FIRE/ SMOKE DAMPERS, FIRE COLLAR/ SLEEVES, INTUMESCENT PUTTY AND FIRE BARRIERS ARE TO BE INSTALLED WHERE DUCTING, PIPEWORK, CABLES, CONTAINMENT AND ANY OTHER SERVICES PASS THROUGH A FIRE WALL/ COMPARTMENT OR FLOOR.
7. ANY DISCREPANCIES BETWEEN THIS DRAWING AND ON SITE CONDITIONS MUST BE REPORTED TO RENAISSANCE ENGINEERING LTD. IMMEDIATELY. ANY CHANGES FROM THIS DESIGN DRAWING MUST BE AGREED WITH THE ENGINEER IN WRITING. A FAILURE TO GAIN THIS APPROVAL COULD LEAD TO DIFFICULTY IN APPROVING PAYMENT FOR THE VARIATION(S).
8. INSTALLATION/ CONSTRUCTION/ AS-BUILT DRAWINGS TO BE PREPARED WITH REFERENCE TO THE LATEST ARCHITECTS AND STRUCTURAL ENGINEERS CONSTRUCTION ISSUE DRAWINGS AND LATEST FIRE CERTIFICATE DRAWINGS.
9. ALL WORKS TO COMPLY WITH THE NATIONAL CODE OF PRACTICE FOR CUSTOMER INTERFACE 4th EDITION 2008.

LIGHTING LEGEND:

 29W LUMISTREET GEN2 MICRO BGP391 4000K DW50 20 LED 5.04m, FITTINGS MOUNTED ATOP 6m POLES (3NO)

Rev.	Date	Revision Description	Drn.	Chk'd.
P1	07.01.21	ISSUED FOR INFORMATION	GB	BS
P	08.09.20	ISSUED FOR INFORMATION	GB	BS


Renaissance Engineering Ltd.
 2nd Floor, 67-70 Meath Street, Dublin 8, D08 XY53.
 telephone: +353 (0) 1 675 0850
 email: info@reng.ie
 web: www.renaissanceengineering.ie


Cavan County Council
 Cavan Courthouse, Farnham St.
 Abbeyland, Cavan, H12 R6V2
 telephone: +353 (0) 49 437 8300
 email: info@cavancoco.ie
 web: www.cavancoco.ie

Architect:
WGG ARCHITECTS & SURVEYORS LTD

Job Title:
HOUSING DEVELOPMENT AT KINNYPOTTLÉ, CAVAN TOWN CO. CAVAN

Drawing Title:
SITE LIGHTING SERVICES LAYOUT

Date:	Scale:	Job No.:	Drawing No.:	Revision:
07.09.20	1:200 @A1	20-168	63-S0	P1
Designer:	Checked:	Approved:	CAD Filename: 20-168-63-S0.dwg	
GB	BS	SM		