

General Notes:

- This drawing is to be read in conjunction with all relevant Architects and Structural Engineers Construction issued drawings, Fire Certificate and Fire Drawings, along with the consultants Mechanical and Electrical specifications and any other documentation.
- Do not scale from this drawings. This drawings is representative only. All dimensions are in millimeters (mm), unless otherwise stated. Use the figured dimensions when shown.
- The exact location of all services and fittings to be agreed on site with the Architect and/or Structural Engineer prior to their installation.
- The Mechanical and Electrical Services are to be coordinated with all other trades and to be agreed on site prior to their installation. The contractor shall allow for the setting out and installation around all obstructions. Additional costs incurred by the contractor due to the lack of coordination will not be accepted.
- Connections to all equipment to be made by the contractor.
- Any discrepancies between this drawing and on site conditions must be reported to Renaissance Engineering LTD. immediately. Any changes from this design drawing must be agreed with the Engineer in writing. A failure to gain the approval could lead to difficulty in approving payment for the variation(s).
- Installation / Construction / As-Built Drawings to be prepared by the Mechanical/Electrical Contractor with reference to the latest Architects and Structural Engineers construction issue drawings and fire certificate drawings.
- All Electrical works to comply with the National Rules for Electrical Installations, 5th Edition IS10101:2020.
- All Mechanical and Electrical works to comply with the current Building Regulations.
- All works to comply with the National Code of Practice for Customer Interface 5th Edition 2021.


- Legend**
- ESB 125mm Duct (@600 BFGL)
 - ESB 50mm Duct (@600 BFGL) From Mini-Pillar to Dwelling
 - ESB Mini Pillar (EMP) (1000x1300x900d)
 - EIR 100mm Duct (@400 BFGL)
 - EIR 32-50mm Duct (@400 BFGL) From Chamber to Dwelling
 - EIR Chamber (EC) JB4 - (910x440x800d)
 - 110mm Virgin Media Duct
 - Feeder Cable (18/14mm Microduct)
 - EIR Chamber (EC) JB4 - (910x440x800d)
 - Street Lighting 100mm (@600 BFGL)
 - ESB Lighting Mini Pillar (1000x1300x900d)
- LIGHTING LEGEND:**
- 20W LUMISTREET GEN2 MICRO 6CP291 D1H50 LED-HB 5.2S 730, FITTINGS MOUNTED ATOP 6M POLES

ALL PUBLIC LIGHTING TO BE DESIGNED AND INSTALLED IN ACCORDANCE WITH ALL CAVAN COUNTY COUNCIL REQUIREMENTS

- ESB LIGHTING MINI PILLAR (LMP-01)
- ESB MINI PILLAR (EMP-01)
50mm Ø ESB DUCT FROM MINI PILLAR TO EACH DWELLING
- 50mm Ø ESB DUCT FROM MINI PILLAR TO SERVE PUBLIC LIGHTING MINI PILLAR (LMP-01)
- NEW EIR CHAMBER (EC-01)
50mm DUCT FROM CHAMBER TO EACH DWELLING
- NEW VIRGIN MEDIA CHAMBER (VC-01)
50mm DUCT FROM CHAMBER TO EACH DWELLING
- 100mm DUCT FOR PUBLIC LIGHTING
- NEW INCOMING 1100MM VIRGIN MEDIA/SIRO DUCT CONNECTED TO NEW EIR VIRGIN MEDIA/SIRO CHAMBER (EC-01)
- NEW INCOMING 1100MM EIR DUCT CONNECTED TO NEW EIR CHAMBER (EC-01)
- NEW INCOMING 1250MM ESB DUCT CONNECTED TO NEW ESB MINI PILLAR (EMP-01)

EXTENSION

DRIVEWAY



Rev.	Date	Revision Description	Drn.	CHK'd.
P4	04.10.23	Issued for Planning	SMcD	SM
P3	13.09.23	Issued for Planning	SMcD	SM
P2	28.07.23	Issued for Planning	SMcD	SM
P1	19.06.23	Issued for Planning	SMcD	SM
P	09.06.23	Issued for Planning	SMcD	SM

RE Renaissance Engineering
 Address: 2nd Floor, 67-70 Meath Street, Dublin 8, D08 YCK4, Ireland
 Telephone: +353 (0)1 675 0850
 Email: info@reng.ie
 Web: renaissanceengineering.ie

Status Code: -----

Client: Cavan Co. Co.

Architect: Wynne Gormley Gilsean

Job Title: Housing Units, Kinalack - Co. Cavan
Main Street Development

Drawing Title: Coordinated Services
Barrack Road

Scale: 1:100 @A1

Drawing No.: 22216-REN-BR-SS-DR-ME-0001

Revision: P4

Approved By: _____

CAD Filename: 22216-REN-BR-SS-DR-ME-0001.dwg